

Addendum 1, January 28, 2010

Tanner Geomembrane Cover Installation Project

Amador Water Agency, Sutter Creek

Contractor to acknowledge receipt of this addendum in his bid.

1. Special Provisions, item 31 shall read as follows: “The Owner shall be provided with a 20-year warranty covering materials ~~and workmanship~~; full warranty for 10 years and prorated for another 10 years. The warranty shall not exclude any of the chemicals that are used in the potable water treatment process in the clear well or at the Tanner water plant. The Owner uses the following chemicals: sodium hypochlorite, a cationic polymer, sodium hydroxide and zinc orthophosphate. The warranty for workmanship shall be at least one year. The Contractor will provide an 11-month warranty inspection for his entire work.
2. Special Provisions, item 33 shall read as follows: “The existing tension system components may be reused ~~as appropriate. Any missing hardware, including bolts and nuts, shall be provided by the contractor as part of the installation work. Any new hardware that the Contractor’s system requires must be provided by the Contractor as part of the installation work.~~ The Contractor shall assume a five percent replacement rate for batten bolts for bidding purposes based on one inch long, one-half inch diameter, grade five bolts. Current batten bolt spacing is approximately 1 bolt per three feet of perimeter. Costs for bolts shall be part of providing and installing the cover. Contractor shall reuse all tension cables.”
3. Special Provisions, new item 44 shall read as follows: “The existing hatch shall be reused and reset into the new cover in the same location in the clear well. The float material inside the floating step system leading up to and surrounding the hatch may be reused. The floating step system shall be recreated in the new cover in the same location in the clear well as the existing floating step system.”
4. Section 5.32.1 of the Contract documents has been corrected. Work on the total project shall be completed within 90 calendar days. Delete the number 30. Bids and work shall be based on a 90-day completion period.